

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

426/2
No. F6/DFS/MS/WZ/2020/58

Dated: 14/02/2020

FIRE SAFETY CERTIFICATE

Certified that the building Maharaja Agarsain Public School Located at Ashok Vihar Phase-IV, Delhi - 110052 comprised of Basement + Ground + 3 Upper Floor, was issued FSC vide Letter No. F6/DFS/MS/2016/School/WZ/1553 Dated 21-10-2016. The premises was re inspected by the officer concerned of this department on 10-02-2020 in the presence of Sh. Poonam Gupta (Principal) and found that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC/BBL1983 and that the premises is fit for occupancy class "Educational" Group B with effect from 14/02/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/02/2020 at New Delhi by.

DALNIA SOT



DDERSB

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

2256/DF
26/02/2020

27/2/20
Copy to:-

1. The Principal, Maharaja Agarsain Public School, Ashok Vihar Phase-IV, Delhi - 110052.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. The FSC shall be null & void if the basement is being used for any school activities & stairs & exits are kept under lock & key.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. All the exits including staircases shall be maintained free from any obstruction.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The basement shall be used as per BBL1983.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

26/2/2020